PRINTED: 10/15/2012 FORM APPROVED

Indiana State Department of Health

NAME OF PROVIDER OR SUPPLIER  WATERS OF PRINCETON THE  WATERS OF PRINCETON THE  STREET ADDRESS, CITY, STATE, 2IP CODE 1020 W VINE 5T PRINCETON, IN 47670  PROVIDER'S RAN OF CORRECTION  REGULATORY OR LSC IDENTIFYING INFORMATION)  K 000  INITIAL COMMENTS  A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.  Survey Date: 10/12/12  Facility Number: 000175  Provider Number: 155275  AIM Number: 100274440  Surveyor: Lex Brashear, Life Safety Code Specialist  At this Quality Assurance Walk-thru survey, The Waters of Princeton was found in compliance with 410 IAC 162-31-19(ff).  This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a related same system with hard wired smoke detectors in the condions, spaces open to the corridors, and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 95 and had a census of 66 at the time of this survey.  The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.  All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered, except one detached wood shed and one detached metal pod, both structures used for facility storage.  Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 10/12/12.	AND PLAN OF CORRECTION IDENTI		(X1) PROVIDER/SUPPLIER/SIDENTIFICATION NUMBER	IDENTIFICATION NUMBER:		(X2) MULTIPLE CONSTRUCTION  A. BUILDING  B. WING		(X3) DATE SURVEY COMPLETED  10/12/2012	
PRETIX TAG  INITIAL COMMENTS  A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.  Survey Date: 10/12/12  Facility Number: 000175 Provider Number: 155275 AIM Number: 100274440  Surveyor: Lex Brashear, Life Safety Code Specialist  At this Quality Assurance Walk-thru survey, The Waters of Princeton was found in compliance with 410 IAC 16.2-3.1-19(ff).  This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and battery operated smoke detectors in the resident sleeping rooms. The facility has a capacity of 95 and had a census of 66 at the time of this survey.  The facility was found in compliance with state law in regard to sprinklere coverage and smoke detector overage.  All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered, except one detached wood shed and one detached metal pod, both structures used for facility storage.  Quality Review by Robert Booher, Life Safety	NAME OF PROVIDER OR SUPPLIER			1020 W VIN	STREET ADDRESS, CITY, STATE, ZIP CODE 1020 W VINE ST				
A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.  Survey Date: 10/12/12  Facility Number: 000175 Provider Number: 155275 AIM Number: 100274440  Surveyor: Lex Brashear, Life Safety Code Specialist  At this Quality Assurance Walk-thru survey, The Waters of Princeton was found in compliance with 410 IAC 16.2-3.1-19(ff).  This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 95 and had a census of 66 at the time of this survey.  The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.  All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered, except one detached wood shed and one detached metal pod, both structures used for facility storage.  Quality Review by Robert Booher, Life Safety	PREFIX	(EACH DEFICIENCY MUST BE PRECEDED BY FU			PREFIX	(EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE		COMPLETE	
	K 000	A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.  Survey Date: 10/12/12  Facility Number: 000175 Provider Number: 155275 AIM Number: 100274440  Surveyor: Lex Brashear, Life Safety Code Specialist  At this Quality Assurance Walk-thru survey, The Waters of Princeton was found in compliance with 410 IAC 16.2-3.1-19(ff).  This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 95 and had a census of 66 at the time of this survey.  The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.  All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered, except one detached wood shed and one detached metal pod, both structures used for facility storage.  Quality Review by Robert Booher, Life Safety		The e of tem dors, eping had ate ke ccess / hed th	K 000				

Indiana State Department of Health

TITLE (X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE